



NEECO II-Area 2, Inc.

AAA- Classified by National Electrification Administration
Mega Large Electric Cooperative – 10 Towns and 1 City

Headquarters: Maharlika Highway, Diversion,
San Leonardo, 3102 Nueva Ecija, Philippines
Main Phone Number: (044)-940-9040

September 21, 2026

SUPPLEMENTAL BULLETIN NO. 1

Dated (ITB No. 2026-09-01) September 5, 2026

TO: ALL REGISTERED BIDDERS

This Supplemental Bulletin is hereby issued to modify and/or amend certain provisions of the Bidding Documents. It shall form an integral part of the Bidding Documents, and all bidders are hereby advised to take note of the following clarifications and amendments.

I. LOT A – ELECTRIC DISTRIBUTION HARDWARES

CLARIFICATION ON THE TECHNICAL SPECIFICATIONS

Supply of Various Materials for Line Maintenance and Warehouse Stock for the Second Half of 2026: Electric Distribution Hardware's (Lot A)

This document is issued to clarify the technical specifications for the above-mentioned procurement, as discussed during the Pre-Bid Conference held on September 15, 2026, at the NEECO II – Area 2 Main Office.

The following clarifications shall form part of the bidding requirements and shall be considered in the preparation and submission of bids.

MAIN CONCERNS AND CLARIFICATIONS

1. List of Items to Be Excluded from the Bidding

The following items shall be excluded from the bidding, and bidders shall no longer include them in their respective bids:

- a. Cluster Box, 6 kWh-Meter Capacity – 1,500 pcs
- b. CT & PT Base – 30 pcs
- c. CT Box, FM:3S – 80 pcs
- d. Fabricated Billing Box (3-1/2" × 6" × 3") – 100 pcs
- e. Meter Base, Rectangular, 4 Jaws (Milbank) – 30 pcs
- f. Meter Box, FM:2S – 112 pcs
- g. Multi-Meter Box, FM-9A – 10 pcs

All other items and requirements under Lot A shall remain unchanged, unless otherwise amended or clarified through a subsequent Supplemental Bulletin or official communication issued by NEECO II – Area 2.

II. LOT B – CONDUCTORS / WIRES

CLARIFICATION ON THE TECHNICAL SPECIFICATIONS

Supply of Various Materials for Line Maintenance and Warehouse Stock for the Second Half of 2026: Conductors / Wires (Lot B)

Corporate e-mail: neecoii_area2@yahoo.com | Telefax: (044) 940 9040 | Website: neeco2area2.com

Facebook: /neeco2a2 | Substation Hotline: Santa Rosa – 0932 889 3445 Bongabon – 0932 889 3447

San Leonardo – 0932 889 3446 Peñaranda – 0925 686 8944 Gabaldon – 0925 7313 816 Gen. Natividad – 0932 8893 448

Corporate Thrust: Vision – An Energy Secured Community Banking On A Smart Electric Cooperative

Mission – To Deliver Quality Electric Services And Programs Anchored On Strong Partnerships Towards Community Development

Core Values – Solidarity, Productivity, Integrity, Courtesy, and Excellence





NEECO II-Area 2, Inc.

AAA-Classified by National Electrification Administration
Mega Large Electric Cooperative – 10 Towns and 1 City

Headquarters: Maharlika Highway, Diversion,
San Leonardo, 3102 Nueva Ecija, Philippines
Main Phone Number: (044)-940-9040

This document is issued to clarify the technical specifications for the above-mentioned procurement, as discussed during the Pre-Bid Conference held on September 15, 2026, at the NEECO II – Area 2 Main Office.

The following clarifications shall form part of the bidding requirements and shall be considered in the preparation and submission of bids.

MAIN CONCERNS AND CLARIFICATIONS

1. Minimum Cut Length per Reel/Roll for Wire Items

All wire items listed below shall comply with the specified minimum cut length per reel or roll:

- a. Conductor, Bare, ACSR #336 – minimum of 1,000 meters per reel
- b. Conductor, Duplex Wire #2 – minimum of 1,000 meters per reel
- c. Conductor, Duplex Wire #6 – The original quantity of 30,000 meters is hereby revised to 100,000 meters, as agreed upon during the Pre-Bid Conference held on September 15, 2026. The minimum cut length shall be 500 meters per roll, supplied in donut type, without a reel.
- d. Conductor, Insulated, ACSR #1/0 Poly – minimum of 2,000 meters per reel
- e. Conductor, Insulated, ACSR #2/0 Poly – minimum of 2,000 meters per reel
- f. Conductor, Insulated, ACSR #4/0 Poly – minimum of 2,000 meters per reel

2. Submission of Wire Samples

All bidders shall submit a minimum of one (1) meter sample for each wire item being offered, for purposes of physical inspection and verification.

The samples shall be submitted **no later than September 30, 2026**, which is one (1) day after the scheduled opening of bids.

All other items and requirements under Lot B shall remain unchanged, unless otherwise amended or clarified through a subsequent Supplemental Bulletin or official communication issued by NEECO II – Area 2.

III. LOT C – SPECIAL PROTECTION EQUIPMENTS

CLARIFICATION ON THE TECHNICAL SPECIFICATIONS

Supply of Various Materials for Line Maintenance and Warehouse Stock for the Second Half of 2026: Special Protection Equipments (Lot C)

This document is issued to clarify the technical specifications for the above-mentioned procurement, as discussed during the Pre-Bid Conference held on September 15, 2026, at the NEECO II – Area 2 Main Office.

The following clarifications shall form part of the bidding requirements and shall be considered in the preparation and submission of bids.

MAIN CONCERNS AND CLARIFICATIONS

1. Cut-Out & Comb., 15kV, 100A

The specified material shall be **POLYMER** instead of **PORCELAIN**.

2. Power Capacitor, 7620V, 50kVAR (Double Bushing)

Corporate e-mail: neecoii_area2@yahoo.com | Telefax: (044) 940 9040 | Website: neeco2area2.com

Facebook: [/neeco2a2](https://www.facebook.com/neeco2a2) | Substation Hotline: Santa Rosa – 0932 889 3445 Bongabon – 0932 889 3447

San Leonardo – 0932 889 3446 Peñaranda – 0925 688 8944 Gabaldon – 0925 7313 816 Gen. Natividad – 0932 889 3 448

Corporate Thrust: Vision – An Energy-Secured Community Banking On A Smart Electric Cooperative

Mission – To Deliver Quality Electric Services And Programs Anchored On Strong Partnerships Towards Community Development

Core Values – Solidarity, Productivity, Integrity, Courtesy, and Excellence





NEECO II-Area 2, Inc.

AAA-Classified by National Electrification Administration
Mega Large Electric Cooperative – 10 Towns and 1 City

Headquarters: Maharlika Highway, Diversion,
San Leonardo, 3102 Nueva Ecija, Philippines
Main Phone Number: (044)-940-9040

The country of origin shall include the **United States of America (USA)** among the acceptable countries of origin.

3. Current Transformer, Extended Range (ERCT)

The technical specifications shall be as follows:

- Voltage Rating: 15.5 kV
- Frequency: 60 Hz
- Current Ratio: 30/5A
- Accuracy Class: 0.15S
- Burden: 0.5
- Rating Factor (RF): 1.5
- Standard: IEEE C57.13
- Weight: 19 kg

4. Potential Transformer (PT)

The technical specifications shall be as follows:

- Voltage Rating: 15.5 kV
- Voltage Ratio: 8400V/120V
- Ratio: 70:1
- Type: Single Bushing
- Accuracy Class: 0.3
- Burden: 25 VA
- Weight: 25 kg

5. Current Transformer, ERCT, 100:5A

The technical specifications shall be as follows:

- Current Ratio: 100:5A
- Voltage Rating: 600V
- Accuracy Class: 0.15
- Burden: B0.2
- Rating Factor (RF): 1.5
- Weight: 6.5 kg

6. Current Transformer, ERCT, 200:5A

The technical specifications shall be as follows:

- Current Ratio: 200:5A
- Voltage Rating: 600V
- Accuracy Class: 0.15
- Burden: B0.5

Corporate e-mail: neeco2area2@yahoo.com | Telefax: (044) 940 9040 | Website: neeco2area2.com

Facebook: [neeco2area2](https://www.facebook.com/neeco2area2) | Substation Hotline: Santa Rosa – 0932 989 3445 Bongabon – 0932 889 3447

San Leonardo – 0932 889 3446 Peñaranda – 0925 688 8944 Gabaldon – 0925 7313 816 Gen.Natividad – 0932 889 3 448

Corporate Thrust: Vision – An Energy-Secured Community Banking On A Smart Electric Cooperative

Mission – To Deliver Quality Electric Services And Programs Anchored On Strong Partnerships Towards Community Development

Core Values – Solidarity, Productivity, Integrity, Courtesy, and Excellence





NEECO II-Area 2, Inc.

AAA- Classified by National Electrification Administration
Mega Large Electric Cooperative – 10 Towns and 1 City

Headquarters: Maharlika Highway, Diversion,
San Leonardo, 3102 Nueva Ecija, Philippines
Main Phone Number: (044)-940-9040

- Rating Factor (RF): 1.5
- Weight: 5 kg

All other items and requirements under Lot C shall remain unchanged, unless otherwise amended or clarified through a subsequent Supplemental Bulletin or official communication issued by NEECO II – Area 2.

IV. LOT D – kWh METERS

CLARIFICATION ON THE TECHNICAL SPECIFICATIONS

Supply of Various Materials for Line Maintenance and Warehouse Stock for the Second Half of 2026: kWh Meters (Lot D)

This document is issued to clarify the technical specifications for the above-mentioned procurement, as discussed during the Pre-Bid Conference held on September 15, 2026, at the NEECO II – Area 2 Main Office.

The following clarification shall form part of the bidding requirements and shall be considered in the preparation and submission of bids.

MAIN CONCERNS AND CLARIFICATIONS

1. Meter, kWh, FM1S, Class 100, 2-Wire, 60 Hz, with ERC Seal and Base

The meter shall be compatible with a ring-type meter base.

The Lowest Calculated and Responsive Bidder (LCRB) shall submit the following samples for physical inspection and verification:

- a. kWh meter sample
- b. Meter base sample
- c. Meter ring sample

All other items and requirements under Lot D shall remain unchanged, unless otherwise amended or clarified through a subsequent Supplemental Bulletin or official communication issued by NEECO II – Area 2.

V. SCHEDULE OF OPENING OF BIDS

All registered bidders are hereby instructed to take note of the foregoing amendments and clarifications and to be guided accordingly in the preparation and submission of their respective bids.

The opening of bids shall be conducted on **September 29, 2026**, at the **NEECO II – Area 2 Main Office**, with the following schedules:

- **Lots A and B:** 10:00 AM
- **Lots C and D:** 1:00 PM

All bidders are advised to observe the above-mentioned schedules accordingly.

This Supplemental Bulletin shall form an integral part of the Bidding Documents.

Issued this 21st day of September 2026, at NEECO II – Area 2, San Leonardo, Nueva Ecija.


JOCELYNS. PADERES
PBAC Chairman

Corporate e-mail: neeco2@yahoo.com | **Telefax:** (044) 940 9040 | **Website:** neeco2area2.com

Facebook: /neeco2a2 | **Substation Hotline:** Santa Rosa – 0932 889 3445 Bongabon – 0932 889 3447

San Leonardo – 0932 889 3446 Peñaranda – 0925 688 8944 Gabaldon – 0925 7313 816 Gen. Natividad – 0932 8893 448

Corporate Thrust: Vision – An Energy Secured Community Banking On A Smart Electric Cooperative

Mission – To Deliver Quality Electric Services And Programs Anchored On Strong Partnerships Towards Community Development

Core Values – Solidarity, Productivity, Integrity, Courtesy, and Excellence

